TAMILNADU FIRE AND RESCUE SERVICES

APPENDIX - XII

FIRE SAFETY CERTIFICATE

No : 01 / 2026

R.C.No: 10/ V / VLY / 2026
Dated: 09.01.2026

Certified that the **M/s. SAN ACADEMY** (name of the building or premises) at **Door No.1A, 200 Feet Road, Narayanapuram, Pallikaranai, Chennai – 600100** (address) comprised of ...**Nil**... basement (s) and Ground and Three Floors (upper floors) owned/ occupied by **M/s. SAN ACADEMY** name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of FireService on **08.01.2026** (date of inspection) in the presence of **Mrs.Hemalatha , Principal , M/s San Academy , Door No.1A, 200 Feet Road, Narayanapuram, Pallikaranai, Chennai – 600100** (name and addresses of the Manager/ Secretary or his representative) and that the building / premises is fit for occupancy upto classes **Nursery to Class XII** With effect from **09.01.2026** for a period of **One Year** in accordance with rule and subject to compliance of specific conditions as appended

1. All the Fire Extinguishers have to be recharged placement and maintained periodically as per BIS 2190/2010.
2. Periodical Maintained should be ensured to keep all fire production equipments and system always in good condition.
3. National building code-2016 Fire & Life safety part-IV should be followed.
4. Fire Drill should be conduct as per NBC-2016.

Issued on .....**09.01.2026**..... (date of issue) at **Velachery**..... (place) by

*Strike out whichever is not applicable.

FIRE & RESCUE STATION
Date: 09.01.2026
VELACHERY, CHENNAI - 600 042.

STATION OFFICER
VELACHERY FIRE & RESCUE STATION
CHENNAI - 600 042.

To:
M/s. SAN ACADEMY,
Door No.1A, 200 Feet Road ,
Narayanapuram, Pallikaranai,
Chennai – 600 100.

Copy To :
1.District Officer, Chennai City South District,
2.Station Officer , Velachery